

20-1

S2W7

- Fire Hydrant -

Location - 2608 Winter Street

Manufacturer - M & H

Size - 4 1/2"

Flow Rate - Static 107 Pitot 26

Pressure - Residual Pressure 26 Residual at 20 will deliver 880

Color Code: Orang

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

3-23-89 D.T.W.

Note any problems -