

22-1

S3E2

- Fire Hydrant -

Location - 954 Lexington Drive

Manufacturer - M & H

3-2/AY

Size - 4 1/2"

Flow Rate - 52 = 1300 Gpm

PD 20th = 1336 GPM

Pressure - STATIC - 140

R-45 = 95

PITOT - 52

FLOW - 1210

1352 - GREEN Code

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

5/3/89 OW

Note any problems -