

4-1

- Fire Hydrant -

S3E2

Location -

921 Lexington Drive

Manufacturer -

M & H

Z-WAY

Size -

Flow Rate -

Static 85

Pitot 50

Pressure -

Residual Pressure 50

Residual at 20 delivers 1682

Date Checked and by Whom

Date Checked and by Whom

Color Code: Green

Date Checked and by Whom

* 25/88 MC Painted

5/4/89 DW

Note any problems -