

11-1

S3W3

- Fire Hydrant -

Location - Pennsylvania Avenue #4 and Drumheller Drive

Manufacturer - M & H 3-WAY 2-3" 1-6"

Size -

Flow Rate - Static 115 Pitot 60

Pressure - Residual Pressure 60 Residual at 20 will deliver 1758

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

Painted 6/8/88 WC

5/2/89 DW

Note any problems -