

16-1

- Fire Hydrant -

S3W4

Location - Shadyside Road and Pennsylvania Avenue

Manufacturer - M & H

1987 New

Size - 5 1/4

Flow Rate - Static 115 Pitot 60

Pressure - Residual Pressure 60

Residual at 20 will deliver 1758

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

Painted 6/8/88 we

5/2/89 DW

Note any problems -