

22-1

- Fire Hydrant -

S3W7

Location - 2609 Mountain View Drive

Manufacturer - M & H

Size - 4 1/2"

Flow Rate - Static 102 Pitot 24

Pressure - Residual Pressure 24

Residual at 20 will deliver 842

Date Checked and by Whom

5-23-89 D.T.W.

Date Checked and by Whom

Color Code: Orange

Date Checked and by Whom

Note any problems -