

10-1

- Fire Hydrant -

S3W8

Location - Scenic Drive and 2716 Lakeview Drive (Corner)

Manufacturer - M & H

Size - 4 1/2"

Flow Rate - Residual Pressure 20 Residual at 20 will deliver 787

Pressure - Static 95 Pitot 22

Color Code: Orange

Date Checked and by Whom	Date Checked and by Whom	Date Checked and by Whom
3-23-89 D. J. W.		

Note any problems -