

3-1

O/T
- Fire Hydrant -

S3W8

Location - 2717 Riverside Drive (Riverlake)

Manufacturer - Eddy Valve

Size -

Flow Rate - Static 110 Pitot 5

Pressure - Residual Pressure 4 Residual at 20 will deliver 377

Color Code: Red

Date Checked and by Whom

3-21-89 2.7. W.

Date Checked and by Whom

Date Checked and by Whom

Note any problems -