

3-1 8-1 ?

- Fire Hydrant -

O/T

S4E3

Location - Ben Road at Apartments

Manufacturer - Kennedy

3-WAY

Size - 2 1/2"

Flow Rate - Static 55 Pitot 8

Pressure - Residual Pressure 8 Residual at 20 delivers 475

Date Checked and by Whom

Date Checked and by Whom

Color Code: Red
Date Checked and by Whom

4/25/88 we Painted

5/4/89 DW

Note any problems -