

24-1

O/T

S4W4

- Fire Hydrant -

Location - 316 Delray Drive

Manufacturer -

Size -

Flow Rate - Static 98 Pitot 22

Pressure - Residual Pressure 25 Residual at 20 will deliver 820

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

3-21-89

D.J.W.

Note any problems -