

24-1?

S4W4

Location -

- Fire Hydrant -

Wishful Vista Way (401) #1

Manufacturer -

Kennedy

Size -

Flow Rate - Static 100 Pitot 26

Pressure - Residual Pressure 26

Residual at 20 will deliver 960

Date Checked and by Whom

3-21-89

D.L.W.

Date Checked and by Whom

Color Code: Orange

Date Checked and by Whom

Note any problems -