

5-1

O/T

S4W4

- Fire Hydrant -

Location - Monterey Drive and Valencia Place

Manufacturer - M & H

Size -

Flow Rate - Static 110 Pitot 44

Pressure - Residual Pressure 45 Residual at 20 will deliver 1336

Color Code: Green

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

Painted WC 6/8/88

3-21-89 D.L.W.

Note any problems -