

1-1

O/T

S4W6

- Fire Hydrant -

Location - 2600 Shadyside Drive (Near Fire Station)

Manufacturer - Kennedy

Size -

Flow Rate - Static 110 Pitot 24

Pressure - Residual Pressure 24 Residual at 20 will deliver 857

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

3-22-89

JTW

Note any problems -