

14-1

- Fire Hydrant -

O/T

S4W8

Location - Aliff Lane and Rt. 6/4 (Riverlake)

Manufacturers - M & H

Size -

Flow Rate - Static 45 Pitot 6

Pressure - Residual Pressure 5 Residual at 20 will deliver 411

Color Code: Red

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

3-22-89

J.T.W.

Note any problems -