

2-1

O/T

S5W6

- Fire Hydrant -

Location - Beside the Mastermeter (2180 Bellwood)

Manufacturer - M & H

Size -

Flow Rate - Static 105 Pitot 13

Pressure - Residual Pressure 13 Residual at 20 will deliver 605

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

8-23-89

J. T. W.

Note any problems -