

- Fire Hydrant -

Location - Bellwood Drive - Shadyside Drive above tunnel

Manufacturer - M & H (NEW) 2-3" 1-6" 3-2029

Size -

Flow Rate - Static 52 Pitot 14

Pressure - Residual Pressure 14 Residual at 20 will deliver 629

Color Code: Orange

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

3-23-89 D.T.W.

Note any problems -