

13-1

- Fire Hydrant -

O/T

S7W6

Location - 59 Dogwood Drive

Manufacturer - Mueller

Size -

Flow Rate - 20 lbs. = 751 GPM

Pressure - STATIC - 105

R.P. 32

Date Checked and by Whom

3-22-89 D.T.W.

Date Checked and by Whom

Date Checked and by Whom

Note any problems, -