

20-1

O/T

S7W6

- Fire Hydrant -

Location - Heritage Drive 122

Manufacturer - M & H

Size -

Flow Rate - 10" = 531 GPM

Pressure - STATIC 60

R.P. 28

Date Checked and by Whom

Date Checked and by Whom

Date Checked and by Whom

3-22-89

D.T.W.

Note any problems -