

4-1

- Fire Hydrant -

O/T

S9W7

Location - 10 Lee Street - Riverbend Boulevard

Manufacturer - Mueller

Size -

Flow Rate - 15 lbs = 650 GPM

Pressure - STATIC: 110

R.P. 32

Date Checked and by Whom

3-22-89

D.Y.W.

Date Checked and by Whom

Date Checked and by Whom

Note any problems -